



NOTE:-

1. Fire hydrants shall be medium or tall pattern clockwise closing in accordance with BS 7501977.
2. Hydrant shall be resilient seated.
3. Thrust blocks to be constructed using 20 MPa concrete.
4. Concrete lined steel fittings must be wrapped with an approved form of protective coating.
5. Hydrant markings shall be as per standard drawing sheet 6.17.
6. Heavy duty lids to be used in all trafficked areas.
7. In berm areas polyethylene fire hydrant boxes may be used.



STANDARD DETAIL:

**STANDARD FIRE
HYDRANT
INSTALLATION**

DATE: June 2010
NOT TO SCALE

TCDC NO: SHEET NO: REV:

4000 12