



NOTES:-

1. The layout shall:
 - Have a maximum distance of 50m between the nearest meter bank and extreme of building.
 - Have meter bank(s) accessible in public areas.
2. The meter bank shall be installed at the time of subdivision with fittings and pipes up to the valve in the meter bank. The extent of the public water supply shall be limited to the meters.
3. All ridermains and private service leads to be ducted.
4. Have meter bank(s) accessible in public areas.



STANDARD DETAIL:

**WATER METER BANKS
TYPICAL LAYOUT**

DATE: June 2010
NOT TO SCALE

TCDC NO:

SHEET NO:

REV:

4000

13