


NOTES:-

- *1. No brass reducing nipple for 20mm & 25mm meters.
- *2. Tail piece for 25mm meter does not include check valve.
- *3. Use a separate D/R brass spring check valve for 25mm meter.
- *4. Applies to 15mm meter only.
- *5. All components to be TCDC approved.
- *6. Fire mains are not currently metered in Thames Coromandel District Council.



STANDARD DETAIL:

**SERVICE CONNECTION
DETAIL 15mm 20mm AND
25mm**

DATE: June 2010
NOT TO SCALE

TCDC NO: SHEET NO: REV:

4000 3