



NOTES:-

1. Work must be inspected by the Council representative before any concrete is poured.
2. Concrete strength shall be 20 MPa at 28 days.
3. Excavation shall be fenced and lit at night.
4. Existing concrete to be cut out neatly and removed.
5. Brick or precast concrete paving units may be used only between the property boundary and the rear of the footpath to comply with NZS 3116.1981 Interlocking Concrete Paving.
6. Crossing dimensions to be specifically designed, to accommodate all vehicle types that may be required to access the site.
7. Residential crossings to be minimum 150mm thick. May be reduced to 110mm thick if a layer of 665 mesh used.
8. Crossings shall be minimum of 200mm thick without mesh.



STANDARD DETAIL:

**VEHICLE CROSSING
RESIDENTIAL
(NO K & C)
(TYPE C)**

DATE: June 2010

NOT TO SCALE

TCDC NO:

3000

SHEET NO:

4

REV:

A