



|                           | Diameter >100 | Diameter ≤ 100 | 50mm MDPE |
|---------------------------|---------------|----------------|-----------|
| Trench width minimum      | OD+200        | OD+100         | 100       |
| Blanket thickness minimum | 100           | 50             | 40        |
| Bedding depth minimum     | 75            | 50             | 0 or 50*  |
| Minimum Side fill         | 75            | 50             | 10 - 20   |

\* 50mm required in rock



STANDARD DETAIL:

### WATERMAIN PIPE BEDDING DETAILS

DATE: June 2010  
NOT TO SCALE

TCDC NO:

SHEET NO:

REV:

4000

6